

SAFETY FOR OPERATORS

Protection against electric arc

Integration between Arc Guard System™ TVOC-2 and ABB low-voltage circuit breakers



01 TVOC-2 02 Tmax XT 03

Emax 2

In the last years, a lot of users have raised the question of safety in electrical assemblies with reference to one of the most severe and destructive electro-physical phenomenon: the electric arc.

Such phenomenon generates internal overpressures and results in local overheating which may cause high mechanical and thermal stress in the equipment.

It is necessary to make clear that such phenomenon is an absolutely anomalous and rare event, but since low-voltage switchgear assemblies are the components of the electric installation most subject to maintenance, it is necessary to take safety measures to prevent it. The arc guard system is therefore a natural part of a modern switchgear design.

The operating logic of an arc detector is based on the detection of the light radiation associated with the occurrence of an arc inside the switchboard.

The arcing control system detects the event and sends a tripping signal to the circuit breaker; reaction time of detection is about 1 ms.



04 The figure shows the areas where this device can be positioned inside a switchboard. The ideal solution is to provide the installation with at least one detector for each column, with the consequent reduction to a minimum of the length of the optical fibers carrying the signal.



In cases where the detectors can be exposed to an intensive light (camera flash, direct sunlight, etc.), an additional current sensor can be positioned at the incoming of the main circuit breaker. This unit adds a current condition to the system. In the event of an arc, both the current sensing unit - which detects an "anomalous" current due to the arc fault, as well as the sensor detecting the light radiation associated with the arc, enable the system to intervene and allow the consequent opening of the circuit breaker.

— 05 Current sensing unit





The tripping time of the Arc Guard system, which consists mainly of the circuit breaker and of the unit TVOC-2, is few milliseconds, since it by-passes the tripping of the overcurrent protection of the circuit breaker.

In fact, such protection may be usually delayed due to several installation needs, among which:

- 1. selectivity requirements
- 2. connections of capacitor banks
- 3. electrical components with high inrush currents.

To reduce this tripping time is necessary to use the Ekip Signalling modules installed on Emax 2 and Tmax XT.

In fact, the contacts of this module can be configured and customized according to one's own requirements.

In this case, it is possible to associate the opening of the circuit breaker to each 24V DC signal arriving to the input contact of the module.

This alternative allows the total times to be remarkably reduced since, in this way, they no longer depend on the shunt opening release (SOR), but on the tripping commanded directly by the electronic unit.

Examples of manageable operation logic

TVOC-2 can command up to three different circuitbreakers since it gives the chance to associate a defined number of light sensors to each circuit breaker.

This makes it possible to use arc monitoring in any applications where, due to different plant engineering reasons and in the event of an arc, it is not sufficient the opening of the main circuit breaker (or even of all the three circuit-breakers), but a logic strictly connected to the plant engineering configuration is required.

The following schemes report some examples of these applications.

As indicated in the previous pages, the Arc Guard System remarkably reduces the trip times in the event of an electric arc.

06

As a consequence, it is evident that under these conditions it is not possible to obtain selectivity in the event of internal arc even if the arc is on the load side of an outgoing feeder. The following example illustrates the above.

Figure 6 shows the trip curves of three circuit breakers, one on the supply side (QF1) selective with the two outgoing feeders (QF2-QF3).

As shown, since each light sensor commands the main circuit breaker, in case of an internal arc there shall be a downtime for the whole plant.

Practically, it is as if the circuit breaker on the supply side had a protection function which would make tripping instantaneous, thus making useless all the settings and time delays based on the selectivity study.

Example: Emax 2 time-current LLL 1E5s 1E4s 1E3s opei QF1 100s ************ 10s QF1 1s QF2 QF3 QF3 QF2 0.1s 70 ms 1E-2s LOAD 2 0.1kA 100kA 1E3kA LOAD 1 1kA 10kA QF1: open → LOAD 1 and LOAD 2 not supplied

In order to avoid downtime of all the plant, when selectivity represents a fundamental requirement also under electric arcing conditions, it is possible to exploit the ability of commanding up to three circuit breakers through a single TVOC-2, by assigning to each light sensor the task of opening one of them. In this way, the system is selective also in the event of an electric arc on the load side of an outgoing feeder (in the example on the load side of QF2). The following figure illustrates the above (to simplify, only 5 light sensors of the 30 available have been represented).



QF1 and QF3 closed: LOAD 2 supplied QF2 opened



To get a selective system, each light sensor must not be influenced by the light fluxes which do not affect its area. Then, it is necessary that some obstacles are positioned between the sensors (typically the metal enclosure of the cubicles) as shown in the figure.

Furthermore, the light sensors must be positioned in a "strategic" way (after a thorough analysis and not accidentally) to define the affected areas and the operating zones.

This is much easier in large power distribution switchboards where the internal dimensions and the metalwork structure allow the separation of the sensors according to their relevant operating areas.

ABB SACE A divison of ABB S.p.A. L.V. Breakers Via Pescaria, 5 24123 Bergamo - Italy Phone: +39 035 395.111 Fax: +39 035 395.306-433

07

abb.com/lowvoltage

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB does not accept any responsibility whatsoever for potential errors or possible lack of information in this document. We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB. Copyright© 2017 ABB All rights reserved